

SAMPLE ANALYSIS REPORT

Report No.	5010F2012
------------	-----------

Lab Sample No.:	5010F2012
Sample Description:	MARMORINO CLASSICO COD. 947
Date of Order:	13/11/2012
Date of analysis:	14/11/2012
Report Date:	19/11/2012

Name and address of test sponsor:	COLORIFICIO SAN MARCO spa Via Alta, 10 – 1 ^A Z.I. 30020 – Marcon (VE) Italy
-----------------------------------	--

Sampling

The test sample was supplied by the test sponsor. Studio ASA was not involved in the sampling process and therefore cannot comment upon the relationship between the samples supplied for test and the product supplied to market.

Conditioning

The sample was conditioned in accordance with the test standard.

Test Results

Test Item	Test Methods	Result (MJ/kg)	European Class of Reaction to Fire (*)
Gross heat of combustion (calorific value)	ISO 1716:2010	0,3	A1

(*) Classification based on Annex to Commission of the European Communities Decision 2000/147/EC, Table 1, applied to any external non-substantial component of non-homogeneous products.

The results relate only to the items tested.

The test report should only be reproduced in extenso – in extracts only with a written agreement with this laboratory.

Signed for and on behalf of Studio ASA



Reinaldo Tomasi
Dr. Reinaldo Tomasi

Studio ASA

Via Paludetti, 30 – Treviso (Italy)
Tel. +39 0422 431200 – Fax +39 0422 431191
e-mail: info@asalab.it – web: www.asalab.it
Laboratorio Accreditato UNI EN ISO/IEC 17025: 2005